

**PRODUCT LINE:** ACCESS

**PRODUCT:** ACT365

**MODEL:** ACU 1.1.27                      **CATEGORY:** FIRMWARE

**CONTACT:** Local Technical Support    **DATE:** 2019-01-15

The following firmware enhancements are to support new features that will be available with the next release of the ACT365 portal. The estimated release date of this is 1 February 2019.

**Feature:**

- Intruder panel: Arm/disarm.
- Twin users.

**Bug Fixes:**

- Timed action has been normalized, which was causing doors to lockout on power cycle.
- Invalid SSL/TLS certificate which was checking and preventing ACU from reconnecting after a communications error. This caused controllers to go offline and power cycle after 30 minutes. The reset reason was no server response (EPIC 11230).